WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 16923
Permit No.
Basin

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Swift Builders ADDRESS Gardnerville Nevada

2. LOCATION ¼ ¼ Sec. 10 T. 12 N/S R. 21 E. Douglas County
PERMIT NO. Lot Number 24 - Fish Springs

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Silt - some		0	22	22
broken Rock.				
Coarse gravel		22	30	8
and clay -				
Some Water				
at 30 feet.				
Rock and		30	70	40
cobble stones				
some clay -				
More water at				
70 feet -				
		70	100	30
Coarse gravel &				
sand - water -				
				100

Date started Sept 14, 1977
Date completed Sept 20, 1977

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 20 Draw down 0 feet 2 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 8 inches Total depth 100 feet
Casing record 100 feet
Weight per foot Thickness .188

Diameter	From	To
8 5/8 inches	0 feet	100 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal feet
Gravel packed: Yes ☐ No ☒
Gravel packed from feet to feet

Perforations:
Type perforation factory
Size perforation
From 86 feet to 100 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 22 Feet below land surface
Flow G.P.M.
Water temperature 60 °F. Quality very good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Clyston W. Graham
Address Gardnerville Nevada
Nevada contractor's license number 12953
Nevada driller's license number 751
Signed C W Graham
Date Sept 21 - 77

USE ADDITIONAL SHEETS IF NECESSARY

5471