



Log No. 16933

Permit No.

Basin

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER O. D. Soble ADDRESS Youngton, Nev 89427

2. LOCATION S¹/₄ NW¹/₄ Sec 32 T. 14 N. R. 26 E 7400 County
PERMIT NO. #18712 27' north of old well

| | | | | | | | | | | |
|----|--|--------------------------------------|--------------------------------|------------------------------------|-------------------------------------|--|-------------------------------|----|--------------------------------|--|
| 3. | TYPE OF WORK | | | 4. | PROPOSED USE | | | 5. | TYPE WELL | |
| | New Well <input checked="" type="checkbox"/> | Recondition <input type="checkbox"/> | Other <input type="checkbox"/> | | Domestic <input type="checkbox"/> | Irrigation <input checked="" type="checkbox"/> | Test <input type="checkbox"/> | | Cable <input type="checkbox"/> | Rotary <input checked="" type="checkbox"/> |
| | Deepen <input type="checkbox"/> | | | Municipal <input type="checkbox"/> | Industrial <input type="checkbox"/> | Stock <input type="checkbox"/> | | | | |

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|------------------------|--------------|------|-----|------------|
| Clay | | 0 | 3 | 3 |
| Fine Sand & Gravel | | 3 | 15 | 12 |
| Coarse Sand & Gravel X | | 15 | 80 | 65 |
| Clay & Gravel | | 80 | 83 | 3 |
| Coarse Sand & Gravel X | | 83 | 145 | 62 |
| Clay & Gravel | | 145 | 150 | 5 |
| Coarse Sand & Gravel X | | 150 | 249 | 99 |

8. WELL CONSTRUCTION

Diameter hole 22 inches Total depth 249 feet

Casing record

Weight per foot _____ Thickness 5/16

| Diameter | From | To |
|------------------|----------------|-----------------|
| <u>14</u> inches | <u>12</u> feet | <u>247</u> feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |

Surface seal: Yes No Type _____

Depth of seal _____ feet

Gravel packed: Yes No

Gravel packed from 0 feet to 247 feet

Perforations:

Type perforation Factory Dowed

Size perforation 3/32 x 3" x 14 rods

From 47 feet to 249 feet

From _____ feet to _____ feet

9. WATER LEVEL

Static water level 23 Feet below land surface 21

Flow _____ G.P.M.

Water temperature _____ ° F. Quality _____

Date started July 19, 1977

Date completed Aug 1, 1977

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|-------------|-------------|-----------|------------------|
| <u>1800</u> | <u>1500</u> | <u>41</u> | <u>24</u> |
| _____ | _____ | _____ | _____ |
| _____ | _____ | _____ | _____ |

BAILER TEST

G.P.M. 50 Draw down _____ feet _____ hours

G.P.M. _____ Draw down _____ feet _____ hours

G.P.M. _____ Draw down _____ feet _____ hours

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Ogden? Paul Pilling

Address 150 Bath Taylor

Nevada contractor's license number 6580

Nevada driller's license number 634

Signed Larry Ogden

Date Aug 1, 1977