WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 16934
Permit No.
Basin

1. OWNER Swift Builders ADDRESS 1031 Riverview-Gardnerville

Fish Springs Estates Lot #28

2. LOCATION NW ¼ ¼ Sec. 5 T. 12 N/S R. 21 E. Douglas County

PERMIT NO.

3. TYPE OF WORK
New Well [X] Recondition [ ]
Deepen [ ] Other [ ]

4. PROPOSED USE
Domestic [X] Irrigation [ ] Test [ ]
Municipal [ ] Industrial [ ] Stock [ ]

5. TYPE WELL
Cable [X] Rotary [ ]
Other [ ]

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
~~XXXXXXX~~ Bolders		0	25	25
Clay & Gravel		25	95	70
Gravel	W/B	95	113	18
Clay		113	118	5

Date started Sept. 15, 19 77
Date completed Spet. 22, 19 77

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 10 Draw down 30 feet 2 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 8 inches Total depth 118 feet
Casing record 8 5/8
Weight per foot Thickness .188

Diameter	From	To
8 inches	1 feet	118 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes [X] No [ ] Type Cement
Depth of seal 50 feet
Gravel packed: Yes [ ] No [X]
Gravel packed from feet to feet

Perforations:
Type perforation Factory Cut
Size perforation 1/8
From 93 feet to 113 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 50 Feet below land surface 0
Flow G.P.M. 10
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Steve House
Address P. O. Box 2192
Nevada contractor's license number 12236-A
Nevada Pump and Drilling
Nevada driller's license number 637
Signed Steve House
Date Sept 22 - 1977

USE ADDITIONAL SHEETS IF NECESSARY

5471