WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 16959
Permit No.
Basin

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Swift Builders ADDRESS Gardnerville Nevada
Lot #29 - Fish Springs

2. LOCATION ¼ ¼ Sec. 6 T. 12 N/S R. 21 E. Douglas County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Silt & Rock -		0	4	4
Hard Boulders some very large		4	35	31
Hard packed gravel and Rubble stones tough drilling		35	82	47
Water at 40				
Some at 75 —				
				82

Date started Sept 21, 1977
Date completed Sept 27, 1977

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. approx 15 Draw down 30 feet 2 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 8 inches Total depth 82 feet
Casing record
Weight per foot Thickness 188

Diameter	From	To
8 5/8 inches	0 feet	82 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 40 to 50 feet
Gravel packed: Yes ☐ No ☒
Gravel packed from feet to feet

Perforations:
Type perforation torch
Size perforation ½ x 3 —
From 68 feet to 82 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 31 Feet below land surface
Flow G.P.M.
Water temperature 60 ° F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Austin W. Graham
Address Gardnerville - Nevada
Nevada contractor's license number 12953
Nevada driller's license number 751
Signed A W. Graham
Date Sept 29 - 1977

USE ADDITIONAL SHEETS IF NECESSARY

5471