WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 17687
Permit No.
Basin

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Neel Manoukian ADDRESS Minden NV.
Antony Villa Dr.

2. LOCATION ¼ ¼ Sec. 10 T. 12 N/S R. 19 E. Douglas County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay & D.G.		1	18	
D.G. & Boulders		19	103	
Clay & D.G.		104	132	
D.G. & Gravel	X	133	195	
Boulder		196	198	

Date started Oct. 12, 19 77
Date completed Oct. 14, 19 77

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 6 inches Total depth 198 feet
Casing record 198'
Weight per foot ..... Thickness 1/4

Diameter	From	To
6 inches	1 feet	198 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Neat Cement
Depth of seal 50' feet
Gravel packed: Yes ☐ No ☐
Gravel packed from ..... feet to ..... feet

Perforations:
Type perforation Factory slot
Size perforation 3x1/16
From 175 feet to 195 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 122 Feet below land surface 122
Flow ..... G.P.M. 30
Water temperature Cold °F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Kawchack Pump & Well Service Inc.
Address Box 536 Gardnerville, Nev.
Nevada contractor's license number 9511-A
Nevada driller's license number 763
Signed Tony Kawchack
Date Oct 15, 1977

USE ADDITIONAL SHEETS IF NECESSARY

5471