WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 17093
Permit No.
Basin

1. OWNER JOhn Royce Construction ADDRESS P.O. Box 1326 Reno, Nevada 89504

2. LOCATION ¼ ¼ Sec. 25 T. 21N N/S R. 18 E. Washoe County
PERMIT NO. x 8900 Little Creek; Silver Knolls

3. TYPE OF WORK
New Well [X] Recondition [ ]
Deepen [ ] Other [ ]

4. PROPOSED USE
Domestic [XX] Irrigation [ ] Test [ ]
Municipal [ ] Industrial [ ] Stock [ ]

5. TYPE WELL
Cable [ ] Rotary [XX]
Other [ ] AIR

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown clay		0	5	5
White & Black sand & gravel fine ¾"		5	20	15
Brown sandy clay fine		20	30	10
Vari colored sand & gravel fine½" loose		30	40	10
Brown sandy clay fine		40	45	5
Brown sandy clay fine ½" med in layers		45	49	4
Blue green sandy clay fine med layers		49	75	26
Green, Brown & Blue sandy clay fine med in layers		75	85	10
Brown sandy clay fine		85	87	2
Brown sand coarse		87	95	8
Brown sandy ;clay coarse		95	105	10
Brown sandy clay		105	125	20

Test hole

Date started 9-19-77, 19
Date completed 9-21-77, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
AIR BLOWN:	52 GPM @	45' depth	
	110 GPM @	75', depth	

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 6 inches Total depth 92 feet
Casing record 0 - 92' x 6 5/80D
Weight per foot 12.89 Thickness .188

Diameter	From	To
10 inches	0 feet	50 feet
8½ inches	50 feet	92 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes [X] No [ ] Type transit mix
Depth of seal 50' feet
Gravel packed: Yes [ ] No [XX]
Gravel packed from feet to feet

Perforations:
Type perforation factory mill slot
Size perforation 1/8 x 2½"
From 71 feet to 92 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 20' Feet below land surface
Flow G.P.M.
Water temperature cold ° F. Quality not tested

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name W.L. McDonald & Co., Inc.
Address P.O. Box 404; Sparks, NV 89431
Nevada contractor's license number 9767
Nevada driller's license number 805
Signed Tony Betita by W.L. McDonald
Tony Betita by: WL. McDonald
Date 22 September. 1977

USE ADDITIONAL SHEETS IF NECESSARY

5471