

OFFICE USE ONLY
 Log No. 17050
 Permit No.
 Basin

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Peter Pagni ADDRESS Rt. #1 Box 189
 Sparks, Nevada 89431

2. LOCATION 1/4 1/4 Sec. 1 T. 19N N/S R. 20 E Washoe County
 PERMIT NO. Prater and Donati

3. TYPE OF WORK
 New Well Recondition
 Decpen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other AIR

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
15% brown clay & boulders				
65% & 20% brown sands		0	25	25
15% black rock & 75% red rock & 10% fine sands		25	150	125
20% black rock 60% red rock 20% fine brown sand		150	175	25
60% black rock & 20% red rock w/ fine sands		175	200	25
Lot more black rock & very little red rock		200	225	25
Black rock w/ red & yellow mixed in		225	260	35
Red rock & black & yellow sands		260	275	15
Red rock & fine yellow & blackish gray sands		275	300	25
Red rock		300	350	50
Redish green & brown rock		350	375	25
More green about 60% red and some brown rock		375	440	65
Green rock 80% & 20% red brown and yellow rock chips are about fine to med in size		440	450	10
The cuttings are turning more brown now & drilling a little faster		450	455	5
Yellow green brown rock		455	485	30
Date started.....6-6-77....., 19.....				
Date completed.....6-29-77....., 19.....				

8. WELL CONSTRUCTION
 Diameter hole 10 inches Total depth 485 feet
 Casing record 0 - 485' x 6 5/8" ID
 Weight per foot 12.89 Thickness 188

Diameter	From	To
10 inches	0 feet	485 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes No Type transit mix
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 0 feet to 485 feet

Perforations:
 Type perforation factory mill slot
 Size perforation 1/8 x 2 1/2"
 From 2.27 feet to 485 feet
 From feet to feet
 From feet to feet
 From feet to feet
 From feet to feet

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
AIR BLOWN:	6 GPM @	250' depth	
	10 GPM @	300' depth	

9. WATER LEVEL
 Static water level 35 Feet below land surface
 Flow G.P.M.
 Water temperature cold °F. Quality not tested

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name W.L. McDonald & Co., Inc.
 Address P.O. Box 404; Sparks, NV 89431
 Nevada contractor's license number 9767
 Nevada driller's license number 923
 Signed Ed Mondragon by W.L. McDonald
 Ed Mondragon by: W.L. McDonald
 Date 7-1-77

BAILER TEST
 G.P.M. Draw down feet hours
 G.P.M. Draw down feet hours
 G.P.M. Draw down feet hours