4

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 17085
Permit No.
Basin

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Veribuild Inc Skyline Estates ADDRESS 20805 Cook Dr

2. LOCATION ¼ ¼ Sec. 7 T. 17 N/S R. 20 E. Washoe County
PERMIT NO.

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay + Rock		0	200	
Hard Rock	Large	200	210	5 ft
Hard Rock TD		210	230	

Date started October 14, 1977
Date completed October 14, 1977

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	35		1 1/2 hrs

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 9 inches Total depth 230 feet
Casing record 6 5/8 OD
Weight per foot Thickness 188 W

Diameter	From	To
6 5/8 OD inches	170 feet	230 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type CONCRETE
Depth of seal 50 ft feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 50 feet to 230 feet

Perforations:
Type perforation
Size perforation
From 170 feet to 230 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level Feet below land surface
Flow G.P.M.
Water temperature 90 ° F. Quality Good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Robert R Houston
Address PO Box 1725 Sparks, Nv 89431
Nevada contractor's license number
Nevada driller's license number 9160
Signed [signature]
Date Oct 14, 1977

USE ADDITIONAL SHEETS IF NECESSARY

5471