WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 17176
Permit No.
Basin

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Frank Zimmer ADDRESS Wildflower Park 9160 E. Rancho Blvd Bldg 1 Las Vegas

2. LOCATION ¼ ¼ Sec 27 T 17 N/S R 22 E County
PERMIT NO. Lot 131 Unit #3 Sunrise Estates El Dorado Dist

3. TYPE OF WORK: New Well ☒ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☒ Irrigation ☐ Test ☐ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☒ Rotary ☐ Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Soil		0	2	
Gravel		2	4	2
Sandy Clay		4	23	19
Gravel		23	54	31
Clay		54	84	30
Sand	X	84	88	4
Sandy Clay		88	92	4
Gravel		92	93	1
Clay		93	97	4
Gravel		97	110	13
Clay		110	115	

Date started 11/4/77, 19
Date completed 11/8/77, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 20 Draw down 84 feet 2 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 12" 50' 6.5" 8" inches Total depth 115' feet
Casing record 8 5/8
Weight per foot 16.9 Thickness .188

Diameter	From	To
8 inches	0 feet	115 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Concrete
Depth of seal 50 feet
Gravel packed: Yes ☐ No ☒
Gravel packed from feet to feet

Perforations:
Type perforation Factory
Size perforation 3 X 3/32
From 91 feet to 111 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 70 Feet below land surface
Flow G.P.M.
Water temperature Cold F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name W.M. Blair
Address Box 353 Daylight
Nevada contractor's license number 10952
Nevada driller's license number 301
Signed William Blair
Date 11/13/77

USE ADDITIONAL SHEETS IF NECESSARY

S471