WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 17187
Permit No.
Basin

1. OWNER E.A. Woodward ADDRESS 3745 Churchill Carson, Nev 89701

2. LOCATION ¼ Block ¼ Sec. 6 T. 16 N/S R. 20 E. Washoe County
PERMIT NO. Lot #4 Washoe Farms - Above Address

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Clay		0	45	45
Sand & Gravel	X	45	47	2
Sandy Clay		47	62	15
Sand & Gravel	X	62	76	14
Sandy Clay		76	82	6
Sand & Gravel	X	82	92	10
Sandy Clay		92	94	2

Date started 9/20/77, 19
Date completed 9/22/77, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 20 Draw down 5 feet 1/2 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
8" = 50' 8" = 44'
Diameter hole 8 inches Total depth 94 feet
Casing record 8 5/8
Weight per foot 16 Thickness 188

Diameter	From	To
8 inches	0 feet	94 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Concrete
Depth of seal 50 feet
Gravel packed: Yes ☐ No ☒
Gravel packed from feet to feet

Perforations:
Type perforation Factory
Size perforation 3 x 3/32
From 71 feet to 91 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 45 Feet below land surface
Flow G.P.M.
Water temperature 60 °F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name W.M. Blair
Address Box 353 Dayton, Nev
Nevada contractor's license number 10950
Nevada driller's license number 757
Signed Charles Rose
Date 10/2/77

USE ADDITIONAL SHEETS IF NECESSARY

5471