



WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Eugene Probst ADDRESS Youngton, Nevada

2. LOCATION Parcel B 1/4 Sec 29 T. 14 N/S R. 25 E. Lyon County
 PERMIT NO. Sunset Hills

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Fill - with Rock		0	10	10
Fill - sand-gravel-rock		10	55	45
Clay sand-rock		55	60	5
Fill-rock		60	65	5
Clay-sand-rock		65	70	5
Fill-sand-rock		70	100	30
Some clay				
Rock-tight		100	112	12
Rock-gold	X	112	145	27
Rock-tight		145	147	2

8. WELL CONSTRUCTION
 Diameter hole 10 inches Total depth 147 feet
 Casing record 118
 Weight per foot..... Thickness 1.18

Diameter	From	To
6 inches	0	147 feet
inches		feet
inches		feet
inches		feet
inches		feet
inches		feet

Surface seal: Yes No Type Cement
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 142 feet

Perforations:
 Type perforation Daused
 Size perforation 4 3/8" x 3" x 6" roll
 From 127 feet to 142 feet
 From..... feet to..... feet
 From..... feet to..... feet
 From..... feet to..... feet
 From..... feet to..... feet

9. WATER LEVEL
 Static water level 93 Feet below land surface 93
 Flow..... G.P.M.
 Water temperature..... ° F. Quality.....

Date started Sept 22, 1977
 Date completed Sept Oct 2, 1977

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Ogden's Well Drilling
 Address 150 N. Bybee Ln
 Nevada contractor's license number 6510
 Nevada driller's license number 634
 Signed Larry Ogden
 Date Oct 3, 1977

BAILER TEST
 G.P.M. 22 Draw down 4 feet 1/2 hours
 G.P.M. Draw down..... feet hours
 G.P.M. Draw down..... feet hours