WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 17317
Permit No.
Basin 11

1. OWNER TED MERRILL ADDRESS 3100 Mill St Reno
3230 SUN CLOUD CT Washoe

2. LOCATION ¼ ¼ Sec. 10 T. 20 N/S R. 15 E County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐ AIR

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
VALLEY FILL		0	25	25
DG		25	105	
GRAVEL FRACTURED		105	150	
WATER		110 TO 150		

Date started 10-12 1977
Date completed 10-12 1977

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

AIR JET ~~BAILER~~ TEST
G.P.M. 25 Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours

8. WELL CONSTRUCTION
Diameter hole 6 inches Total depth 150 feet
Casing record 6 5/8
Weight per foot ____ Thickness .219

Diameter	From	To
6 5/8 inches	+2 feet	150 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type CEMENT
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 150 feet

Perforations:
Type perforation MILL SLOT
Size perforation 3/32 X 3"
From ____ feet to ____ feet
From 110' feet to 150 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 62 Feet below land surface
Flow ____ G.P.M.
Water temperature ____ ° F. Quality ____

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name BURT DRILLING
Address Box 11324 - RENO - 89510
Nevada contractor's license number 6589
Nevada driller's license number 899
Signed [signature]
Date 10-13-77

USE ADDITIONAL SHEETS IF NECESSARY

5471

77 DEC 15 AM 9:30