WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

393
363

OFFICE USE ONLY
Log No. 17352
Permit No.
Basin

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Goshute Reds. ADDRESS USPI Bureau of Indian affairs 8 Miles South west of Ibapah Nevada

2. LOCATION NE ¼ NW ¼ Sec. 20 T. ~~10 S~~ 24 (N)/S R. 70 E. White pine County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☒ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
top Sial Clay		0	55'	
" " "				
" " "				
" " "				
Med Gravel		55'	60'	
Tight Clay Med Gravel		60'	90'	
" " Soft Sand Stone		90'	100'	
tight Clay Layers Med Gravel		100'	120'	
Tight Gummy Clay		120'	150'	
good Coarse Gravel		150'	154'	
Tight Gummy Clay		154'	190'	
tight Clay Layers Sand Stone Med Gravel		190'	240'	
Tight Clay Med Gravel Layers		240'	260'	
" "		260'	270'	
good Coarse Gravel		270'	282'	
Tight Gummy Clay Thin Layers Gravel		282'	320'	
Tight Gummy Clay		320'	330	
Tight Gummy Clay Thin Layers Sand Stone		330'	360'	
Hard Tight Gummy Clay		360'	400'	

Date started 12-8-77, 19
Date completed 12-12-77, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump (pump level)
0 flowing	750	55	55
55	1250	33	88
88	1450	14	102
102	1650	17	119
119	1850	31	150

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 24" inches Total depth 393'1" feet
Casing record
Weight per foot 40 LB Thickness ¼"

Diameter	From	To
16 inches	0 feet	393 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Concert
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from ~~393~~ 50 feet to ~~393~~ 393 feet
Perforations:
Type perforation Vertical
Size perforation ⅛"
From 147 feet to 393 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
the well was sealed of and a valve was Installed
Static water level 0 Feet below land surface
Flowing G.P.M. 100
Water temperature ° F. Quality Drinkable

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Kent M Smith
Address Ansley Nebr.
Nevada contractor's license number A. J. Const Co Homedall Idaho.
Nevada driller's license number Temporary permit
Signed Kent M Smith
Date 12-16-77

USE ADDITIONAL SHEETS IF NECESSARY

5471