WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 17364
Permit No.
Basin 099

1. OWNER KARL KASTNER ADDRESS 6025 SMOKEY CANYON DRIVE SPARKS, NV 89431

RANCHO HAVEN

2. LOCATION SE ¼ NW ¼ Sec. 20 T. ~~21~~ 23 N/S R. 18 E. WASHOE County

PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
clay		0	58	58
sand	X	58	77	19
clay		77	102	25
sand	X	102	120	18
clay		120	123	3

Date started 9-26, 19 77
Date completed 9-29, 19 77

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
3600	35		12

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 12¼ inches Total depth 123 feet
Casing record 8 5/8" od x 188 wall
Weight per foot 16.94 Thickness 188 wall

Diameter	From	To
12¼ inches	0 feet	123 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type cement
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 123 feet

Perforations:
Type perforation Milled
Size perforation 1/8" x 3"
From 63 feet to 123 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 30 Feet below land surface
Flow G.P.M.
Water temperature 58 °F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name SAGE BROS DRILLING CO., INC.
Address 1500 RANGER ROAD RENO, NV 89506
Nevada contractor's license number 7462A
Nevada driller's license number 774
Signed T.L. Sage
Date OCTOBER 10, 1977

USE ADDITIONAL SHEETS IF NECESSARY

5471