

OFFICE USE ONLY  
 Log No. 17401  
 Permit No. ....  
 Basin. ....

**WELL DRILLERS REPORT**

Please complete this form in its entirety

1. OWNER CARPENTERS RANCH ADDRESS POST OFFICE BOX 428  
EDWARDS CREEK ELKO, NEVADA

2. LOCATION SW 1/4 NW 1/4 Sec. 3 T. 19 N/S R. 37 E. CHURCHHILL County  
 PERMIT NO. ....

3.	TYPE OF WORK			4.	PROPOSED USE			5.	TYPE WELL	
	New Well <input checked="" type="checkbox"/>	Recondition <input type="checkbox"/>	Other <input type="checkbox"/>		Domestic <input type="checkbox"/>	Irrigation <input checked="" type="checkbox"/>	Test <input type="checkbox"/>		Cable <input type="checkbox"/>	Rotary <input checked="" type="checkbox"/>
	Deepen <input type="checkbox"/>			Municipal <input type="checkbox"/>	Industrial <input type="checkbox"/>	Stock <input type="checkbox"/>				

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
surface clay-some rock		0	70	70
hard sandstone		70	200	130
brown sandy clay	XX	200	274	74
hard rock-abrasive		274	361	87
brown clay with boulders		361	378	17
blue grey granite-hard		378	446	68
black vol. rock		446	471	25
blue sandy clay	XX	471	587	116
Fractured hard vol. rock	XX	587	596	9
solid hard vol. black		596	601	5

8. WELL CONSTRUCTION

Diameter hole 24 inches Total depth 601 feet  
 Casing record 16" od x 250 wall  
 Weight per foot 44 Thickness .....

Diameter	From	To
<u>24</u> inches	<u>0</u> feet	<u>601</u> feet
..... inches	..... feet	..... feet
..... inches	..... feet	..... feet
..... inches	..... feet	..... feet
..... inches	..... feet	..... feet
..... inches	..... feet	..... feet

Surface seal: Yes  No  Type .....

Depth of seal..... feet

Gravel packed: Yes  No

Gravel packed from 0 feet to 601 feet

Perforations:  
 Type perforation Milled  
 Size perforation 1/8" x 3"  
 From 91 feet to 601 feet  
 From..... feet to..... feet  
 From..... feet to..... feet  
 From..... feet to..... feet  
 From..... feet to..... feet

Date started JULY 3, 1976  
 Date completed JULY 25, 1976

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>1750</u>	<u>800</u>	<u>340</u>	<u>24</u>
.....	.....	.....	.....
.....	.....	.....	.....

BAILER TEST

G.P.M.	Draw down.....feet	.....hours
.....	.....	.....
.....	.....	.....
.....	.....	.....

9. WATER LEVEL

Static water level 117 Feet below land surface.....  
 Flow..... G.P.M.....  
 Water temperature 59 ° F. Quality good

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name SAGE BROS DRILLING COMPANY, INC.

Address 1500 RANGER ROAD RENO, NV 89506

Nevada contractor's license number 7462A

Nevada driller's license number 615

Signed W.L. Sage

Date DECEMBER 30, 1977