WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 17403
Permit No.
Basin

1. OWNER Blanche F. Hall ADDRESS PO. Box 102 Yerington Nev

2. LOCATION SE ¼ SE ¼ Sec. 16 T. 14.N N/S R. ~~26E~~ 25 E. E. Lyon County
PERMIT NO.

3. TYPE OF WORK
New Well [X] Recondition [ ]
Deepen [ ] Other [ ]

4. PROPOSED USE
Domestic [X] Irrigation [ ] Test [ ]
Municipal [ ] Industrial [ ] Stock [ ]

5. TYPE WELL
Cable [X] Rotary [ ]
Other [ ]

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand Gravel Silt		0	48	48
Clay		48	84	36
Sand and Gravel	11	84	95	11
Clay	~~95~~	95	99	4
Sand and Gravel	~~99~~ 14	99	112	13

Date started Oct. 23, 1977
Date completed Dec. 28, 1977

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 60 Draw down 10 feet 4. hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 6 5/8 inches Total depth 112 feet
Casing record
Weight per foot Thickness .219

Diameter		From		To	
~~zzzzzz~~	inches	~~zzzzz~~	feet	~~zzzzzz~~	feet
6 5/8	inches	~~zz~~ 0	feet	112	feet
	inches		feet		feet
	inches		feet		feet
	inches		feet		feet
	inches		feet		feet

Surface seal: Yes [X] No [ ] Type cement
Depth of seal from 5 to 50 feet
Gravel packed: Yes [ ] No [X]
Gravel packed from feet to feet

Perforations:
Type perforation Factory Sawed
Size perforation 1/16th 8rows
From 100 feet to 108 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 15 Feet below land surface
Flow G.P.M.
Water temperature cold °F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Clifford Thompson
Address Rt 2 po box 1050 Yerington Nev
Nevada contractor's license number
Nevada driller's license number 855
Signed Clifford Thompson
Date January 5. 1978

USE ADDITIONAL SHEETS IF NECESSARY

5471