

OFFICE USE ONLY
Log No. 17423
Permit No. _____
Basin _____

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER James Guisti ADDRESS 572-12th Elko, NV 89801

2. LOCATION Bullion road
N.W. 1/4 N.W. 1/4 Sec. 28 T. 34 N/S R. 55 E. Elko County
PERMIT NO. _____

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/>	Domestic <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/>	Cable <input checked="" type="checkbox"/> Rotary <input type="checkbox"/>
Deepen <input type="checkbox"/> Other <input type="checkbox"/>	Municipal <input type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/>	Other <input type="checkbox"/>

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Sand & clay</u>		<u>0</u>	<u>20</u>	<u>20</u>
<u>Sand</u>	<u>✓</u>	<u>20</u>	<u>31</u>	<u>11</u>
<u>Blue clay</u>		<u>31</u>	<u>107</u>	<u>76</u>
<u>Sand w/water</u>	<u>✓</u>	<u>107</u>	<u>115</u>	<u>8</u>
<u>Clay</u>		<u>115</u>	<u>124</u>	<u>9</u>
<u>T.D. 124</u>				

8. WELL CONSTRUCTION

Diameter 6 inches Total depth 124 feet
Casing record 12.5 ft. 6 3/8"
Weight per foot 12.92 Thickness 1.89

Diameter	From	To
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type Portland Cement
Depth of seal 55 ft. feet
Gravel packed: Yes No
Gravel packed from 55 feet to 124 feet

Perforations:
Type perforation Mill cut
Size perforation 1/8" x 3" x 12 ft.
From 10.5 feet to 12.3 feet
From _____ feet to _____ feet

9. WATER LEVEL

Static water level 18 Feet below land surface
Flow _____ G.P.M.
Water temperature Cold ° F. Quality good

Date started 12/10, 1977
Date completed 12/20, 1977

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. <u>45</u>	Draw down <u>15</u> feet	<u>1</u> hours
G.P.M. _____	Draw down _____ feet	_____ hours
G.P.M. _____	Draw down _____ feet	_____ hours

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name A. Stockton for Muz. H. Drillers Co.
Address 203 Pine St., Elko, NV 89801
Nevada contractor's license number 10819
Nevada driller's license number Stockton 922 - Muz. H. 632
Signed James V. Smith
Date 1/10/78