

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER James Thomas ADDRESS 2950 Harrigan Rd
 Trento Lane Lot
 2. LOCATION SW 1/4 NW 1/4 Sec. 13 T. 19 N/S R. 27 E. Churchill County
 PERMIT NO.

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0	1	1
Sand		1	17	16
Clay		17	19	2
Sand		19	20	1
Clay		20	34	14
Sand (Fine)	✓	34	35	1
Sand (Rough)	✓	35	36	1
Red Clay		36	—	—

8. WELL CONSTRUCTION
 Diameter hole 11 inches Total depth 36 feet
 Casing record
 Weight per foot Thickness .350
 Diameter 6 inches From 0.1 feet To 3.6 feet
 inches feet feet
 Surface seal: Yes No Type Grout
 Depth of seal feet
 Gravel packed: Yes No
 Gravel packed from feet to feet
 Perforations:
 Type perforation
 Size perforation 3/16
 From 2.5 feet to 3.5 feet
 From feet to feet
 From feet to feet
 From feet to feet
 From feet to feet

9. WATER LEVEL
 Static water level 24 Feet below land surface 12
 Flow 1 1/4 G.P.M. 3.0
 Water temperature Cold F. Quality Good

Date started Dec 13, 1977
 Date completed Dec 16, 1977

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
3000	30	2'	12

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Paul N. Pflimlin
 Address 7007 Curry Rd.
 Nevada contractor's license number 10655
 Nevada driller's license number 928
 Signed Paul N. Pflimlin
 Date 12-16-77

BAILER TEST
 G.P.M. Draw down feet hours
 G.P.M. Draw down feet hours
 G.P.M. Draw down feet hours