WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 17534
Permit No.
Basin

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Spencer Bitz ADDRESS Tupelo

2. LOCATION SE ¼ NW ¼ Sec. 22 T. 21 N/S R. 19 E. Washoe County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
White Clay		0'	35'	35'
Sandy Clay		35'	42'	7'
Clay / No Sand		42'	63'	21'
Sandy Clay		63'	106'	43'
Coarse sand Streaks	*	106'	111'	5'
Sandy Clay		111'	115'	4'
Coarse Sand	* *	115'	122'	7'
Sandy Clay		122'	125'	3'

Date started Dec. 22, 19 77
Date completed Dec. 30, 19 77

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 15 Draw down 50 feet 1 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 6" inches Total depth 125' feet
Casing record
Weight per foot Thickness 188

Diameter	From	To
6" inches	0 feet	125 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Ready-mix
Depth of seal 60' feet
Gravel packed: Yes ☐ No ☒
Gravel packed from feet to feet

Perforations:
Type perforation ~~3/32~~ Mill
Size perforation 3/32
From 85' feet to 125' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 30' Feet below land surface
Flow G.P.M. 15
Water temperature Cool ° F. Quality Clear

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Jim V. Enloe / Enloe Drilling Co
Address Box 235, Janesville, Ca. 96114
Nevada contractor's license number 4739 A
Nevada driller's license number 794
Signed Jim V. Enloe
Date Jan. 4, 1978

USE ADDITIONAL SHEETS IF NECESSARY

5471