

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Richard Junta ADDRESS P.O. Box 62
Virginia City, NV 89440

2. LOCATION NW 1/4 NW 1/4 Sec. 32 T. 18N N/S R. 21 E Washoe County
PERMIT NO. Sec C Lot 789 Cartwright

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/>	Domestic <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/>	Cable <input type="checkbox"/> Rotary <input checked="" type="checkbox"/>
Deepen <input type="checkbox"/> Other <input type="checkbox"/>	Municipal <input type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/>	Other <input type="checkbox"/> AIR

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown top soil fine fast		0	1	1
Purple gray rock fine to chips 1/2"		1	25	24
Purple gray rock fine to med slow		25	48	23
Gray granite fine to med slow		48	85	37
Red rock 1/2" fine slow		85	120	35
Gray rock & white clay 1/2" fine slow some fractured areas but no water		120	150	30
Gray rock fine slow		150	175	25
Gray rock fine slow no water		175	200	25
Redish purple andesite little granite broken rock slow maybe little water		200	218	18
Gray, green, purple granite 1/2-1/2" broken rock med little more water		218	245	27
Gray fractured granite fine to med slow possible water		245	265	20
Gray granite fine slow		265	270	5
Black rock chips 1/2-1/4" WATER		270	290	20

8. WELL CONSTRUCTION

Diameter hole 6 inches Total depth 290' feet
Casing record 0 - 290' x 6 5/8 O.D.
Weight per foot 12.89 Thickness 188

Diameter	From	To
10 inches	0 feet	50 feet
8 1/2 inches	50 feet	290 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes No Type transit mix
Depth of seal 50' feet
Gravel packed: Yes No
Gravel packed from feet to feet

Perforations:
Type perforation factory mill slot
Size perforation 1/8 x 2 1/2"
From 270 feet to 290 feet
From feet to feet
From feet to feet
From feet to feet

Date started 11-15-77, 19.....
Date completed 11-18-77, 19.....

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
AIR BLOWN:	47 GPM @	175' depth	
	62 GPM @	225' depth	

9. WATER LEVEL

Static water level 100' Feet below land surface
Flow G.P.M.
Water temperature cold °F. Quality not tested

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name W.L. McDonald & Co., Inc.
Address P.O. Box 404; Sparks, NV 89431
Nevada contractor's license number 9767
Nevada driller's license number 923
Signed Ed Mondragon By: W.L. McDonald
Date Ed Mondragon by: W.L. McDonald
18 November, 1977

BAILER TEST

G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours