

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Mike McKay ADDRESS 600 Lancaster
Reno, Nevada 89506

2. LOCATION $\frac{1}{4}$ $\frac{1}{4}$ Sec. 3 T. 20N N/S R. 19 E Washoe County
 PERMIT NO. 7550 Rocky Point Trail Golden Valley

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/>	Domestic <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/>	Cable <input type="checkbox"/> Rotary <input checked="" type="checkbox"/>
Deepen <input type="checkbox"/> Other <input type="checkbox"/>	Municipal <input type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/>	Other <input type="checkbox"/> AIR

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown decomposed granite sand coarse to 1/8"		0	6	6
Gray & brown rock sandy clay to 1/2" in size		6	12	6
Gray decomposed granite sand coarse to 1/8"		12	20	8
Black & white & gray granite fine & chips hard		20	28	8
Gray granite fine slow		28	40	12
Brown clay & granite broken rock coarse med		40	55	15
Gray granite fine slow		55	80	25
Brown broken rock coarse med broken rock & clay		80	95	15
Gray granite fine slow		95	100	5
Gray granite 1/2-1/4"		100	150	50
Gray granite fine slow		150	160	10
Black w/ green fractured rock chips to 1/2" size		160	170	10
Gray granite fine slow		170	195	25
Black white & gray fractured rock chips to 1/2"		195	220	25
WATER				

8. WELL CONSTRUCTION

Diameter hole.....6.....inches Total depth.....220' feet
 Casing record.....0 - 220' x 6 5/8 O.D.
 Weight per foot.....12.89.....Thickness.....188.....

Diameter	From	To
10 inches	0 feet	50 feet
8 1/2 inches	50 feet	220 feet

Surface seal: Yes No Type transit mix
 Depth of seal.....50' feet
 Gravel packed: Yes No
 Gravel packed from..... feet to..... feet

Perforations:
 Type perforation factory mill slot
 Size perforation.....1/8 x 2 1/2"
 From.....180 feet to.....220 feet
 From..... feet to..... feet
 From..... feet to..... feet
 From..... feet to..... feet
 From..... feet to..... feet

9. WATER LEVEL

Static water level.....150.....Feet below land surface.....
 Flow.....G.P.M.....
 Water temperature cold °F. Quality not tested

Date started.....11-18-77....., 19.....
 Date completed.....11-22-77....., 19.....

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
AIR BLOWN	8.59 GPM @ 175'	depth	
	24.75 GPM @ 200'	depth	

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name W.L. McDonald & Co., Inc.
 Address P.O. Box 404; Sparks, NV 89431
 Nevada contractor's license number 9767
 Nevada driller's license number 805
 Signed T. Betita by W.L. McDonald
 Date Tony Betita by: W.L. McDonald
30 November, 1977

BAILER TEST

G.P.M. Draw down.....feethours
 G.P.M. Draw down.....feethours
 G.P.M. Draw down.....feethours