

Log No. 17650
 Permit No. _____
 Basin 109

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER John Shipley ADDRESS Green Acres
Springton Nev. 89447
 2. LOCATION NE 1/4 SW 1/4 Sec. 11 T. 14 N/S R. 25 E. 25 County Esmeralda
 PERMIT NO. _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand		0	2	2
Clay		2	12	10
Sand & Gravel		12	50	38
Green Colored				
Green Clay		50	57	7
Gravel & Sand		57	64	7
Sand				
Clay & Gravel		64	66	2
Gravel & Sand		66	70	4
Sand				
Green Clay		70	84	14
Gravel & Sand		84	109	25

8. WELL CONSTRUCTION
 Diameter hole 10 inches Total depth 109 feet
 Casing record _____
 Weight per foot _____ Thickness 109

Diameter	From	To
<u>6</u> inches	<u>0</u> feet	<u>109</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type Cement
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 109 feet
 Perforations:
 Type perforation Saver
 Size perforation 1/2 x 3 x 6 holes
 From 50 feet to 109 feet
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 10 Feet below land surface 10
 Flow _____ G.P.M.
 Water temperature _____ ° F. Quality _____

Date started Feb 16, 1978
 Date completed Feb 22, 1978

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	<u>30</u>	<u>2</u>	<u>1 hr</u>

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Osborn's Well Drilling
 Address 150 N. Pyle Ave. Ln.
 Nevada contractor's license number 6580
 Nevada driller's license number 634
 Signed Larry Osborn
 Date 2-23-78

BAILER TEST
 G.P.M. 22 Draw down 1 feet 1 hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours