

OFFICE USE ONLY
 Log No. 17653
 Permit No. _____
 Basin _____

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER LARRY TRENTAM ADDRESS 1195 LA VIA WAY
SPARKS, NEVADA 89431

2. LOCATION 1/4 Sec. 22 T. 21N N/S R. 19E E WASHOE County
 PERMIT NO. WX 265 Oregon Street Lemon Valley

3. TYPE OF WORK			4. PROPOSED USE			5. TYPE WELL							
New Well	<input checked="" type="checkbox"/>	Recondition	<input type="checkbox"/>	Domestic	<input checked="" type="checkbox"/>	Irrigation	<input type="checkbox"/>	Test	<input type="checkbox"/>	Cable	<input type="checkbox"/>	Rotary	<input checked="" type="checkbox"/>
Deepen	<input type="checkbox"/>	Other	<input type="checkbox"/>	Municipal	<input type="checkbox"/>	Industrial	<input type="checkbox"/>	Stock	<input type="checkbox"/>	Other	<input type="checkbox"/>	Air	

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Decomposed Granite		0	15	15
Hard Rock Gray		15	27	12
Decomposed granite with clay streaks brown		27	85	58
Decomposed granite with soft streaks brown		85	110	25
Very Soft decomposed granite is brown	X	110	125	15
Decomposed granite with soft streaks		125	145	20
Decomposed granite soft zone brown		145	154	19
Decomposed granite very soft brown	X	154	170	16 21
Decomposed granite with soft streaks brown		170	185	15
Hard Rock Gray		185	192	7
Brown	X	192	207	12

8. WELL CONSTRUCTION

Diameter hole 6 inches Total depth 207 feet
 Casing record 207' 6-5/8" OD
 Weight per foot _____ Thickness 188

Diameter	From	To
<u>6-5/8</u> inches	<u>0</u> feet	<u>207</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type Cement
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 207 feet

Perforations:
 Type perforation Factory Sawn Slots
 Size perforation 3/32" X 2-1/2 X 6 Around

From	feet to	feet
<u>98</u>	<u>118</u>	feet
<u>138</u>	<u>158</u>	feet
<u>178</u>	<u>198</u>	feet

Date started 1-21, 1978
 Date completed 2-2, 1978

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M.	Draw down	feet	hours

9. WATER LEVEL

Static water level 82 Feet below land surface
 Flow 20 G.P.M.
 Water temperature _____ ° F. Quality _____

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WAYNE DRILLING, INC.
 Address P.O. BOX 347 Newcastle Ca.
 Nevada contractor's license number 14043
 Nevada driller's license number 908
 Signed [Signature]
 Date 2-3-78