DIVISION OF WATER RESOURCES

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 17745
Permit No.
Basin Truckee Sec.

1. OWNER Carlsberg Development Corp. (Virginia City Highlands) ADDRESS % Hydro-Search; 333 Flint Street, Reno, Nevada

2. LOCATION SW ¼ SE ¼ NE ¼ Sec. 6 T. 17N N/S R. 21 E. Storey County

PERMIT NO.

3. TYPE OF WORK
New Well [X] Recondition [ ]
Deepen [ ] Other [ ]

4. PROPOSED USE
Domestic [ ] Irrigation [ ] Test [X]
Municipal [ ] Industrial [ ] Stock [ ]

5. TYPE WELL
Cable [ ] Rotary [X]
Other [ ]

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness

Date started 9-7-72, 19
Date completed 9-11-72, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 8 inches Total depth 290 feet
Casing record
Weight per foot 12.82 Thickness .188

Diameter	From	To
X 6 5/8OD inches	0 feet	~~290~~ 120 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes [ ] No [X] Type
Depth of seal (test hole) feet
Gravel packed: Yes [ ] No [ ]
Gravel packed from feet to feet

Perforations:
Type perforation factory milles slot
Size perforation 1/8 X 2½
From 60 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 71 Feet below land surface
Flow G.P.M.
Water temperature 58 °F. Quality see attached report

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name W.L. McDonald & Co.
Address 1955 18th Street; Sparks, Nev.
Nevada contractor's license number 9767
Nevada driller's license number 493
Signed W L McDonald
Date 11-21-72

USE ADDITIONAL SHEETS IF NECESSARY