WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 17797
Permit No.
Basin 84

1. OWNER Jim Holman & Pamela Parcel ~~7245~~ 7225 ADDRESS Palomino Valley 6480 Whiskey Spring Rd

RC 4-13-04

2. LOCATION SE ¼ SW ¼ Sec. 07 T. 22 N/S R. 22 E. Washoe County
PERMIT NO. APN 077-320-02

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	6	6
rock & boulders in clay		6	18	12
Clay Base				
green rock formation		18	68	50
Clay with Sand & Gravel		68	105	37
unconsolidated Rock		105	117	12
Clay with sand & Gravel		117	128	11
unconsolidated Rock		128	140	12
Clay with sand & Gravel		140	146	6
Rock with streaks of		146	245	99
clay				

RECEIVED 04 APR -1 AM 10:54 STATE ENGINEER'S OFFICE

Date started March 18, 1978
Date completed March 21, 1978

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
656 cfm 750 lbs	300	90	2 HR

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
10" To 50'
Diameter hole 8 5/8 To bottom inches Total depth 245 feet
Casing record 6 5/8
Weight per foot 12.9 Thickness .156

Diameter		From		To	
6 5/8	inches	0	feet	246	feet
	inches		feet		feet
	inches		feet		feet
	inches		feet		feet
	inches		feet		feet
	inches		feet		feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 245 feet

Perforations:
Type perforation Factory
Size perforation 1/16 X 3½
From 200 feet to 246 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 110 Feet below land surface
Flow 30 G.P.M.
Water temperature Cool °F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Aqua Drilling & Well Service Inc
Address Box 2143 Carson City Nev 89701
Nevada contractor's license number 14327
Nevada driller's license number 900
Signed Robert J. Foster
Date March 22, 1978

USE ADDITIONAL SHEETS IF NECESSARY

5471