

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Western General ADDRESS Lebo Nevada

2. LOCATION SW 1/4 SW 1/4 Sec 15 T. 21N N/S R. 19 E. Washoe County
 PERMIT NO. 1071 Block 12 Appleton Sub # 3 11292 Chesapeake Terminal Valley

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0	8	8
sandy clay with some gravel		8	86	78
large gravel & sand		86	120	34
O.G. coarse sand & varied gravel	✓	120	138	18

8. WELL CONSTRUCTION
 Diameter hole 8 3/8 to bottom inches Total depth 138 feet
 Casing record 6 7/8
 Weight per foot 12.9 Thickness .156

Diameter	From	To
<u>6 7/8</u> inches	<u>0</u> feet	<u>138</u> feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

 Surface seal: Yes No Type Cement
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 138 feet
 Perforations:
 Type perforation factory
 Size perforation 1/4 x 3/8
 From 118 feet to 138 feet
 From _____ feet to _____ feet

Date started March 28, 1978
 Date completed March 29, 1978

9. WATER LEVEL
 Static water level 70 Feet below land surface
 Flow 8 G.P.M.
 Water temperature cold ° F. Quality clear

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>650 CFM 250 PSI</u>	<u>8</u>	<u>20</u>	<u>3 HR</u>

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Aqua Drilling & Well Serv. Inc.
 Address Box 2143 Carson City Nev.
 Nevada contractor's license number 14327
 Nevada driller's license number 900
 Signed Robert J. Foster
 Date 3/29/78

BAILER TEST

G.P.M.	Draw down	feet	hours
.....
.....
.....