

WELL DRILLERS REPORT

*Superior const. Co.*

Please complete this form in its entirety

1. OWNER Ken Mitchell ADDRESS PO Box 151 Shampart NV 89436  
Lot 11 on Coyote Washed City  
2. LOCATION 1/4 1/4 Sec. 31 T. 17 N/S R. 22 E Washed County  
PERMIT NO. \_\_\_\_\_

3. TYPE OF WORK  
New Well  Recondition   
Deepen  Other   
4. PROPOSED USE  
Domestic  Irrigation  Test   
Municipal  Industrial  Stock   
5. TYPE WELL  
Cable  Rotary   
Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SAND + Clay		0	20	20
SAND + Clay + GRAVEL		20	50	30
SAND + Clay		50	54	4
SAND	16	54	70	16
SAND + GRAVEL	30	70	100	30
SAND	10	100	110	10

8. WELL CONSTRUCTION  
Diameter hole 6 inches Total depth 110 feet  
Casing record 110  
Weight per foot \_\_\_\_\_ Thickness 188  
Diameter From To  
6 inches 0 feet 110 feet  
\_\_\_\_ inches \_\_\_\_\_ feet \_\_\_\_\_ feet  
Surface seal: Yes  No  Type Cement  
Depth of seal 50 feet feet  
Gravel packed: Yes  No   
Gravel packed from none feet to none feet  
Perforations: Factory Perf.  
Type perforation \_\_\_\_\_  
Size perforation 1/16 x 3/16  
From 86 feet to 106 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 3/11, 1978  
Date completed 3/14, 1978

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST  
G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

9. WATER LEVEL  
Static water level 60 Feet below land surface 35  
Flow Good G.P.M. 20  
Water temperature Cold ° F. Quality \_\_\_\_\_

10. DRILLERS CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Kawchack Pump & Well  
Address P.O. Box 536 Gardnerville  
Nevada contractor's license number 9511-A  
Nevada driller's license number 942  
Signed Joe N. McElroy  
Date 3/15/78