

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER DON SUNDT ADDRESS 9045 TURBINE WAY
RENO, NEVADA 89506

2. LOCATION 1/4 Sec. 22 T. 21N N/S R. 19E E WASHOE County
 PERMIT NO. 11680 CHESAPEAKE LEMON VALLEY

3. TYPE OF WORK New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/> Deepen <input type="checkbox"/> Other <input type="checkbox"/>	4. PROPOSED USE Domestic <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/> Municipal <input type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/>	5. TYPE WELL Cable <input type="checkbox"/> Rotary <input checked="" type="checkbox"/> Other <input type="checkbox"/> AIR
------------------------------------------------------------------------------------------------------------------------------------------------------------------------	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	---------------------------------------------------------------------------------------------------------------------------------

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sandy Clay		0	55	55
Sand		55	60	5
Brown Clay		60	75	15
Sand		75	80	5
Sandy Clay		80	110	30
Sand	X	110	115	5
Sandy Clay		115	140	25
Sand with some gravel	X	140	155	15
Brown Clay		155	160	5

8. WELL CONSTRUCTION
 Diameter hole 6 inches Total depth 151 feet
 Casing record 151' og 6-5/8" OD
 Weight per foot _____ Thickness 188

Diameter	From	To
_____ inches	_____ feet	_____ feet
<u>6-5/8</u> inches	<u>0</u> feet	<u>16.1</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type Cement
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 151 feet
 Perforations:
 Type perforation Factory Sawed Slots
 Size perforation 3/32" X 2 1/2 X 6 Around
 From _____ feet to _____ feet
 From 111 feet to 151 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 50 Feet below land surface
 Flow 14 G.P.M.
 Water temperature _____ ° F. Quality _____

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WAYNE DRILLING, INC.
 Address P.O. BOX 347 NEWCASTLE CA.
 Nevada contractor's license number 14043
 Nevada driller's license number 908
 Signed Wayne C. Hademan
 Date 3-20-78

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours