WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 17852
Permit No.
Basin 11

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER NEVADA HOMES, INC. ADDRESS 640 SIERRA STREET RENO, NEVADA 89502

2. LOCATION ¼ ¼ Sec. 10 T. 20N N/S R. 19E E. WASHOE County
~~PERMIT NO~~ 7145 Marlin Golden Valley

3. TYPE OF WORK
New Well [X] Recondition [ ]
Deepen [ ] Other [ ]

4. PROPOSED USE
Domestic [X] Irrigation [ ] Test [ ]
Municipal [ ] Industrial [ ] Stock [ ]

5. TYPE WELL
Cable [ ] Rotary [X]
Other [ ] AIR

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BROWN TIGHT CLAY		0	30	30
BROWN CLAY WITH SOFT		30	45	15
STREAKS		45	85	40
BROWN CLAY		85	90	5
SAND	XX	90	125	35
CLAY				
SAND WITH CLAY	XX	125	145	20

Date started 3-13- 19 78
Date completed 3-14- 19 78

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 6 inches Total depth 135 feet
Casing record 135' of 6-5/8" OD
Weight per foot Thickness .188

Diameter	From	To
inches	feet	feet
6-5/8 inches	0 feet	~~3.812~~ 135 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes [X] No. [ ] Type Cement
Depth of seal 50 feet
Gravel packed: Yes [X] No [ ]
Gravel packed from 50 feet to 135 feet

Perforations:
Type perforation Factory sawed slots
Size perforation 3/32" X 2½ X 6 Around
From feet to feet
From 110 feet to 135 feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 32 Feet below land surface
Flow 14 G.P.M.
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WAYNE DRILLING, INC.
Address P.O. BOX 347 NEWCASTLE CA.
Nevada contractor's license number 14043
Nevada driller's license number ~~988~~ 471
Signed Wayne Hedman
Date 3-20-78

USE ADDITIONAL SHEETS IF NECESSARY

5471

OFFICE
STATE ENGINEER

1978 APR 10 AM 10 27