WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 17855
Permit No.
Basin

1. OWNER Orvill Mowrer ADDRESS 10655 Silver Knolls Blvd

2. LOCATION ¼ ¼ Sec. 25 T. 21 N/S R. 18 E. Washoe County
PERMIT NO.

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SURFACE SAND + SILT		0'	20'	20'
GRAVEL		20'	23'	3'
SAND + SILT		23'	37'	14'
GRAVEL + SAND		37'	40'	3'
CLAY + SAND		40'	73'	33'
CLAY		73'	80'	7'
CLAY + GRAVEL		80'	96	16'
CLAY + SAND + GRAVEL		96'	150'	54'
SAND + CLAY		150'	170'	20'
GRAVEL + SAND		170'	190'	20'
CLAY		190'	200'	10'

Date started MARCH 29, 1978
Date completed March 30, 1978

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 10" inches Total depth 200' feet
Casing record 6" 200'
Weight per foot 10 gage Thickness 180 W

Diameter	From	To
6" inches	0 feet	200 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 50' feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 200 feet

Perforations:
Type perforation torch
Size perforation 3/16 X 8"
From 130 feet to 180 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level Feet below land surface
Flow G.P.M.
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Suchta Well Drlg
Address Sparks Nv.
Nevada contractor's license number 14508
Nevada driller's license number 989
Signed Floyd Suchta
Date 3/30/78

USE ADDITIONAL SHEETS IF NECESSARY

5471