

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER SPENCER B. IZ ADDRESS SPARKS NEV.

2. LOCATION SW 1/4 NW 1/4 MID T.M. Topok St. Leman Valley
SE 1/4 NW 1/4 Sec. 27 T. 21 N. N/S R. 12 E. Washoe County
 PERMIT NO. 22

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/>	Domestic <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/>	Cable <input checked="" type="checkbox"/> Rotary <input type="checkbox"/>
Deepen <input type="checkbox"/> Other <input type="checkbox"/>	Municipal <input type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/>	Other <input type="checkbox"/>

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay		0	50	50
COURSE SAND	-	50	60	10
SANDY CLAY	-	60	111	51
COURSE SAND	-	111	118	7
Clay		118	120	2

8. WELL CONSTRUCTION

Diameter hole 6 inches Total depth 120 feet
 Casing record 7.1-120
 Weight per foot _____ Thickness 1.87

Diameter	From	To
<u>10</u> inches	<u>0</u> feet	<u>50</u> feet
<u>6</u> inches	<u>50</u> feet	<u>120</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type Camel Cement
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from _____ feet to _____ feet

Perforations:
 Type perforation Factory Milled
 Size perforation 3/8"
 From 80 feet to 120 feet
 From _____ feet to _____ feet

Date started _____, 19____
 Date completed _____, 19____

9. WATER LEVEL

Static water level 30 Feet below land surface
 Flow _____ G.P.M.
 Water temperature Cold ° F. Quality good

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Exlor Drilling Co
 Address P.O. Box 370 Carson City
 Nevada contractor's license number 4739
 Nevada driller's license number 590
 Signed Chas. L. Fisher
 Date MARCH 7, 1978

BAILER TEST

G.P.M. 20 Draw down 5 feet 1 hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours