

OFFICE USE ONLY
 Log No. 17945
 Permit No. _____
 Basin _____

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER CLIFF CORBITT ADDRESS 119 Vine Street
Reno, Nevada 89503

2. LOCATION SE⁴/₄ SE⁴/₄ Sec. 2 T. 18N N/S R. 19E E. Washoe County
 PERMIT NO. 3445 Lundsford court

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/>	Domestic <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/>	Cable <input type="checkbox"/> Rotar <input checked="" type="checkbox"/>
Deepen <input type="checkbox"/> Other <input type="checkbox"/>	Municipal <input type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/>	Other <input type="checkbox"/> AIR

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0	3	3
Boulders and gravel with brown clay		3	15	12
Gravel and fine to coarse sand with clay stringers	XX	15	125	105
Water Bearing Fractures found at 65', 88', 115'.				

8. WELL CONSTRUCTION

Diameter hole 6 inches Total depth 125 feet
 Casing record 125' of 6-5/8" OD
 Weight per foot _____ Thickness 188

Diameter	From	To
<u>6-5/8</u> inches	<u>0</u> feet	<u>125</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type Cement
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 125 feet

Perforations:
 Type perforation Factory sawed slots
 Size perforation 3/32" X 2 1/2 X 6 Around
 From _____ feet to _____ feet
 From 80 feet to 120 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Date started 4-18, 1978
 Date completed 4-18, 1978

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. _____	Draw down _____ feet	_____ hours
G.P.M. _____	Draw down _____ feet	_____ hours
G.P.M. _____	Draw down _____ feet	_____ hours

9. WATER LEVEL

Static water level 10 Feet below land surface
 Flow 50+ G.P.M.
 Water temperature _____ ° F. Quality _____

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WAYNE DRILLING, INC.
 Address P.O. Box 347 Newcastle, Ca. 95658
 Nevada contractor's license number 14043
 Nevada driller's license number 471
 Signed Wayne Drilling
 Date 4-21-78