

OFFICE USE ONLY  
 Log No. 17948  
 Permit No.  
 Basin

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER TONY GREENE ADDRESS 7890 Tholl Drive Reno Nevada

2. LOCATION 1/4 1/4 Sec. 32 T. 21N N/S R. 19E E Washoe County  
 PERMIT NO. Ranchero Sub #1 Lot 21 7890 Tholl Drive Reno

|   |  |   |
|---|--|---|
| 3. TYPE OF WORK   | 4. PROPOSED USE  | 5. TYPE WELL  |
| New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/> | Domestic <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/> | Cable <input type="checkbox"/> Rotary <input checked="" type="checkbox"/> |
| Deepen <input type="checkbox"/> Other <input type="checkbox"/>                    | Municipal <input type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/>          | Other <input type="checkbox"/> AIR  |

| 6. LITHOLOGIC LOG                                   |              |      |     |            |
|---|--------------|------|-----|------------|
| Material  | Water Strata | From | To  | Thick-ness |
| Top soil  |              | 0    | 2   | 2          |
| Brown Sticky Clay                                   |              | 2    | 30  | 28         |
| Brown Clay Sandy and Soft                           |              | 30   | 45  | 15         |
| Very Soft Brown Clay                                | X            | 45   | 50  | 5          |
| Medium hard   |              | 50   | 87  | 37         |
| Tight Clay with rock str-eaks.                      |              | 87   | 94  | 7          |
| Very Gray Rock cap                                  |              | 94   | 103 | 9          |
| Medium hard rock tan                                |              | 103  | 124 | 21         |
| Rock  |              | 124  | 131 | 7          |
| Broken and Fractured                                | X            | 131  | 133 | 2          |
| Broken and fractured with clay streaks              |              | 133  | 142 | 9          |
| Very tight hard gravel                              |              | 142  | 151 | 9          |
| Medium soft weathered streaks of decomposed granite |              | 151  | 179 | 28         |
| Soft streaks brown clay                             |              | 179  | 196 | 17         |
| DG with soft streaks                                |              | 196  | 230 | 34         |
| Hard rock   |              | 230  | 235 | 5          |
| Soft Zone   |              | 235  | 238 | 3          |
| Hard Rock   |              | 238  | 242 | 4          |
| soft zone fractures                                 |              | 242  | 249 | 7          |
| Very hard rock                                      |              | 249  | 261 | 11         |
| Soft zone   | X            | 261  | 267 | 6          |
| Hrd broken & fractured                              |              | 267  | 270 | 3          |
| Hard rock   |              | 279  | 293 | 14         |
| Broken and fractured                                |              | 293  | 300 | 7          |

Date started start-4-4-78 complete- 4-4-78, 19.....

| 8. WELL CONSTRUCTION   |                          |           |                      |
|--|--------------------------|-----------|----------------------|
| Diameter hole  | 6                        | inches    | Total depth 300 feet |
| Casing record  | 300 ft. of 6-5/8" OD     |           |                      |
| Weight per foot  | Thickness .188           |           |                      |
| Diameter   | From                     | To        |                      |
| 6-5/8 inches   | 0                        | 300       | feet                 |
| inches   |                          |           | feet                 |
| Surface seal: Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>  | Type                     | 88 cement |                      |
| Depth of seal  | 50 feet                  |           |                      |
| Gravel packed: Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> |                          |           |                      |
| Gravel packed from   | 50                       | feet to   | 300 feet             |
| Perforations:  |                          |           |                      |
| Type perforation   | Factory sawed slots      |           |                      |
| Size perforation   | 3/32" X 2 1/2 X 6 Around |           |                      |
| From   |                          | feet to   |                      |
| 90   |                          | feet to   | 100 feet             |
| 134  |                          | feet to   | 144 feet             |
| 157  |                          | feet to   | 167 feet             |
| 260  |                          | feet to   | 300 feet             |

| 9. WATER LEVEL     |                             |
|--------------------|-----------------------------|
| Static water level | 120 Feet below land surface |
| Flow               | 15 G.P.M.                   |
| Water temperature  | ° F. Quality                |

| 10. DRILLERS CERTIFICATION   |                                  |
|--|----------------------------------|
| This well was drilled under my supervision and the report is true to the best of my knowledge. |                                  |
| Name   | WAYNE DRILLING, INC.             |
| Address  | P.O. BOX 347 NEWCASTLE CA. 95658 |
| Nevada contractor's license number   | 14043                            |
| Nevada driller's license number  | 471                              |
| Signed   | <i>Wayne Adams</i>               |
| Date   | 4-21-78                          |

| 7. WELL TEST DATA |        |           |                  |
|-------------------|--------|-----------|------------------|
| Pump RPM          | G.P.M. | Draw Down | After Hours Pump |
|                   |        |           |                  |
|                   |        |           |                  |
|                   |        |           |                  |
|                   |        |           |                  |

| BAILER TEST |           |      |       |
|-------------|-----------|------|-------|
| G.P.M.      | Draw down | feet | hours |
| G.P.M.      | Draw down | feet | hours |
| G.P.M.      | Draw down | feet | hours |