DIVISION OF WATER RESOURCES

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLERS REPORT

**Please complete this form in its entirety**

OFFICE USE ONLY
Log No. 17995
Permit No.
Basin

1. OWNER Marion M. Stead ADDRESS Sutcliffe Star Route Reno NV

2. LOCATION N.W. ¼ N.W. ¼ Sec. 15 T. 20 N/S R. 20 E. Washoe County
PERMIT NO. 3335

3. TYPE OF WORK
New Well [X] Recondition [ ]
Deepen [ ] Other [ ]

4. PROPOSED USE
Domestic [X] Irrigation [ ] Test [ ]
Municipal [ ] Industrial [ ] Stock [ ]

5. TYPE WELL
Cable [X] Rotary [ ]
Other [ ]

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| D G | | 0 | 18 | 18 |
| Clay | | 18 | 26 | 8 |
| Clay & Sand | | 26 | 28 | 2 |
| Clay | | 28 | 50 | 22 |
| Clay & Sand | w | 50 | 62 | 12 |
| Clay | | 62 | 88 | 26 |
| Brown Clay | | 88 | 127 | 39 |
| Coarse Sand | w | 127 | 131 | 4 |
| Clay | | 131 | 140 | 9 |
| Clay & Sand | | 140 | 144 | 4 |
| Coarse Sand | w | 144 | 150 | 6 |
| Coarse Sand | w | 150 | 165 | 15 |
| Gravel & Sand | w | 165 | 177 | 12 |
| Rock | w | 177 | 187 | 10 |
| Sand | | 187 | 200 | 13 |
| Rock | | 200 | 202 | 2 |

Date started March 17, 1978
Date completed March 31, 1978

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| | | | |

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 8 inches Total depth 202 feet
Casing record 200
Weight per foot ..... Thickness 188

| Diameter | From | To |
|---|---|---|
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes [X] No [ ] Type
Depth of seal 50 feet
Gravel packed: Yes [ ] No [ ]
Gravel packed from ..... feet to ..... feet

Perforations:
Type perforation torch
Size perforation
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 40 Feet below land surface
Flow ..... G.P.M.
Water temperature ..... ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Francis McKay
Address 730 Rosewood Dr Reno NV
Nevada contractor's license number 14170
Nevada driller's license number 514
Signed Francis McKay
Date April 2

USE ADDITIONAL SHEETS IF NECESSARY

5471