

Log No. 18075

Permit No.

Basin.

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER John Keemer ADDRESS P.O. Box 12

2. LOCATION NW 1/4 NE 1/4 Sec. 5 T. 39 N/S R. 69 E. Elko County PERMIT NO.

3. TYPE OF WORK: New Well [checked], Recondition [], Deepen [], Other []. 4. PROPOSED USE: Domestic [checked], Irrigation [checked], Municipal [], Industrial [], Stock []. 5. TYPE WELL: Cable [checked], Rotary [], Other [].

6. LITHOLOGIC LOG

Table with columns: Material, Water Strata, From, To, Thickness. Entries include Soil, Clay & fine sand, loose gravel, cemented gravel, Clay, Gravel thin sand, loose gravel, cemented gravel, gravel - slightly cemented, clay & sand.

8. WELL CONSTRUCTION

Diameter hole 12 inches Total depth 239 feet. Casing record. Weight per foot. Thickness 0.50. Diameter 8 inches From 0 feet To 239 feet. Surface seal: Yes [checked] No []. Type Grout. Depth of seal 50 ft. Gravel packed: Yes [checked] No []. Gravel packed from 50 feet to 190 feet. Perforations: Type perforation Milled (Factory) Size perforation 1/2 x 3. From 53 feet to 239 feet.

9. WATER LEVEL

Static water level 76 Feet below land surface 76. Flow G.P.M. Water temperature 60.1 F. Quality Good.

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name R.D. Reynolds Address Wells, Nevada Nevada contractor's license number 14410 Nevada driller's license number 916 Signed R.D. Reynolds Date 5-16-28

7. WELL TEST DATA

Table with columns: Pump RPM, G.P.M., Draw Down, After Hours Pump. Includes handwritten notes: 12:30 AM 13, 10:10 AM 14.

BAILER TEST

G.P.M. 25 Draw down 0 feet 4 hours. G.P.M. Draw down feet hours. G.P.M. Draw down feet hours.