WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
**DIVISION OF WATER RESOURCES**

OFFICE USE ONLY
Log No. 18767
Permit No.
Basin

# WELL DRILLERS REPORT

**Please complete this form in its entirety**

1. OWNER Johnny Ribeiro Builder, Inc. ADDRESS 1280 Terminal Way Suite #3 Reno, NV 89502

2. LOCATION ¼ NW ¼ Sec. 1 T. 18N N/S R. 19 E. WASHOE County
PERMIT NO.

3. TYPE OF WORK
New Well ☒X Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒XX Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☐
Other ☐ AIR XX

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Brown top soil; fine | | 0' | 1' | 1' |
| Brown sandy clay | | 1' | 6' | 5' |
| Brown-gray andesite 1"-¾" and fine | | 6' | 25' | 19' |
| Brown-gray andesite and rock; ½-¼" chips | | 25' | 75' | 50' |
| Gray andesite; ½-¼" chips | | 75' | 100' | 25' |
| Yellow-brown sand with some gravel; medium to coarse size. First encountered water 105' | | 100' | 130' | 30' |
| Yellow-gray cemented sand and gravel; coarse size; more water | | 130' | 152' | 22' |

Date started May 18, 19 78
Date completed May 18, 19 78

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| AIR BLOWN | 47 GPM @ | 125' | depth |

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 6 inches Total depth 152 feet
Casing record 0 - 152' X 6 5/8" O.D.
Weight per foot 12.89 Thickness .188

| Diameter | | From | | To | |
|---|---|---|---|---|---|
| 10 | inches | 0 | feet | 50 | feet |
| 8½ | inches | 50 | feet | 152 | feet |
| | inches | | feet | | feet |
| | inches | | feet | | feet |
| | inches | | feet | | feet |
| | inches | | feet | | feet |

Surface seal: Yes ☒X No ☐ Type Transit Mix
Depth of seal 50' feet
Gravel packed: Yes ☐ No ☒
Gravel packed from ..... feet to ..... feet

Perforations:
Type perforation Factory cut
Size perforation 1/8" x 2½"
From 132 feet to 152 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 95 Feet below land surface
Flow ..... G.P.M.
Water temperature Cold ° F. Quality Not Tested

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name W. L. McDonald & Company, Inc.
Address P. O. Box 404, Sparks, NV 89431
Nevada contractor's license number 9767
Nevada driller's license number 805
Signed Tony Betita by W. L. McDonald
Tony Betita by: W.L. McDonald
Date May 19, 1978

USE ADDITIONAL SHEETS IF NECESSARY

5471