WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
**DIVISION OF WATER RESOURCES**

# WELL DRILLERS REPORT

**Please complete this form in its entirety**

OFFICE USE ONLY
Log No. [redacted] 18193
Permit No. [redacted]
Basin [redacted]

1. OWNER Jim Brinley ADDRESS

2. LOCATION ¼ ¼ Sec. 3 T. 16 N/S 19 E. County
PERMIT NO.

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Boulders | | 0 | 60 | 60 |
| Clay & Gravel | | 60 | 150 | |
| Sand | WB | 150 | 165 | |
| Clay | | 165 | 175 | |
| Sand | WB | 175 | 197 | |
| Clay | | 197 | 201 | |

Date started 5-3, 1978
Date completed 5-10, 1978

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| | | | |

BAILER TEST
G.P.M. 14 Draw down 5 feet 6 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 6 5/8 inches Total depth 201 feet
Casing record 201
Weight per foot Thickness 188

| Diameter | From | To |
|---|---|---|
| 6 5/8 inches | 0 feet | 201 feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes ☑ No ☐ Type Cement
Depth of seal feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 50 feet to 201 feet

Perforations:
Type perforation Factory
Size perforation 5/32
From 140 feet to 201 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 140 Feet below land surface 140
Flow G.P.M.
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name James House Well Drilling
Address PO Box 351 C.C.
Nevada contractor's license number 12555
Nevada driller's license number 802
Signed 5-12-78 James House
Date 5-12-78

USE ADDITIONAL SHEETS IF NECESSARY

5471