


Log No. 18194
 Permit No. _____
 Basin _____

WELL DRILLERS REPORT

Please complete this form in its entirety



1. OWNER Joe Alotta ADDRESS 1569 Cheyenne Rd.
Johnston
 2. LOCATION $\frac{1}{4}$ $\frac{1}{4}$ Sec. 3 T. 13 N/S R. 19 E. Douglas County
 PERMIT NO. _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Sand</u>		<u>0</u>	<u>9</u>	<u>9</u>
<u>Clay and Sand</u>		<u>9</u>	<u>135</u>	<u>126</u>
<u>Sand</u>	<u>WB</u>	<u>135</u>	<u>140</u>	<u>5</u>
<u>Clay & Gravel</u>		<u>140</u>	<u>145</u>	<u>5</u>
<u>Sand & Gravel</u>	<u>WB</u>	<u>145</u>	<u>179</u>	<u>34</u>
		<u>179</u>	<u>180</u>	<u>1</u>

8. WELL CONSTRUCTION
 Diameter hole 8 5/8 inches Total depth 180 feet
 Casing record 180
 Weight per foot _____ Thickness 180
 Diameter 8 5/8 inches From 0 feet To 180 feet
 _____ inches _____ feet _____ feet
 Surface seal: Yes No Type Cement
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 180 feet
 Perforations:
 Type perforation factory
 Size perforation 5/32
 From 120 feet to 180 feet
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 100 Feet below land surface
 Flow 15 G.P.M.
 Water temperature _____ ° F. Quality _____

Date started 4-24 19 78
 Date completed 5-1 19 78

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
 G.P.M. 15 Draw down 0 feet 5 hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name James House Well Drilling
 Address P.O. Box 351
 Nevada contractor's license number 12554
 Nevada driller's license number 800
 Signed James House
 Date 5-1-78