



WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Security Housing ADDRESS Reno NV  
10405 Wells Fargo Silver Knolls  
 2. LOCATION  $\frac{1}{4}$   $\frac{1}{4}$  Sec 24 T 21 N/S R. 18 E Washoe County  
 PERMIT NO.

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown Clay		0	5	5
Fine Sand		5	20	15
DG SOFT		20	70	50
GRANITE HARD		70	90	20
BROKEN GRANITE		90	117	27
Good WATER				

8. WELL CONSTRUCTION  
 Diameter hole 10 inches Total depth 117 feet  
 Casing record 6"  
 Weight per foot \_\_\_\_\_ Thickness 1.06 gage  

Diameter	From	To
<u>6</u> inches	<u>0</u> feet	<u>117</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes  No  Type CEMENT  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from 50 feet to 117 feet  
 Perforations:  
 Type perforation Torch  
 Size perforation 3/16 x 1/4"  
 From 87 feet to 117 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level \_\_\_\_\_ Feet below land surface \_\_\_\_\_  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_  
 Water temperature \_\_\_\_\_ ° F. Quality \_\_\_\_\_

Date started 4-11 19 78  
 Date completed 4-12 19 78

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

10. DRILLERS CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Security Well Drilling  
 Address Sparks NV  
 Nevada contractor's license number 14508  
 Nevada driller's license number 939  
 Signed Larry Martin  
 Date 4-12-78

BAILER TEST  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours