WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 18361
Permit No. 30121
Basin 2-91

1. OWNER Boomtown ADDRESS Carson Rd Verdi, Nev

2. LOCATION NE ¼ SW ¼ Sec. 16 T. 19 N/S R. 18 E. Wash E County
PERMIT NO. 30121

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
soil		0	2	2
Clay		2	11	9
Clay - Gravel		11	36	25
Clay - Boulders		36	60	30
sand - Boulders		60	110	50
Clay - Boulders		110	120	10
Clay		120	130	10
gravel - Boulders		130	145	15
Clay		145	150	5

Date started 6-1-, 1976
Date completed 7-1-, 1976

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 12 inches Total depth 150 feet
Casing record
Weight per foot ..... Thickness .250

Diameter	From	To
12 inches	1 feet	150 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 100 feet to 150 feet

Perforations:
Type perforation Torch
Size perforation
From 145 feet to 85 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 30 Feet below land surface
Flow ..... G.P.M.
Water temperature Cold F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Marvin Nulling
Address 4340 Hwy 50 E
Nevada contractor's license number 360
Nevada driller's license number
Signed [signature]
Date 6-15-78

USE ADDITIONAL SHEETS IF NECESSARY

5471