WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 18481
Permit No.
Basin

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Joe & Connie Medina ADDRESS 2000 Bench Rd Fallon, NV 89406

2. LOCATION SE ¼ SE ¼ Sec. 18 T. 19 N/S R. 27 E. Churchill County
PERMIT NO. Above Address

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	23	23
Yellow Clay		23	35	12
Sand		35	55	20
Yellow Clay		55	58	3
Sand		58	74	16
Blue Clay		74	94	20
Gravel	X	94	100	6
Blue Clay		100	104	4
Coarse Sand		104	110	6
Yellow Clay		110	112	2
plugged by well log 122821				
replaced by log 122820				

Date started 6-19-78, 19
Date completed 6-21-78, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 10 Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 12" 50' 62' 8" inches Total depth 112 feet
Casing record 8 5/8
Weight per foot 16.9 Thickness 18.8

Diameter	From	To
8 inches	0 feet	112 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Concrete
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 60 feet

Perforations:
Type perforation Factory
Size perforation 3 x 3/32
From 90 feet to 110 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level Feet below land surface 75
Flow No G.P.M.
Water temperature Cold F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name W.M. Blain
Address Box 353 Dayton
Nevada contractor's license number 10950
Nevada driller's license number 963
Signed R.E. O'Farrell
Date 7/8/78

USE ADDITIONAL SHEETS IF NECESSARY

5471

OFFICE
STATE ENGINEER

1978 JUL 11 AM 9 21