WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 18515
Permit No.
Basin

1. OWNER OLMSTEAD COMPANY ADDRESS 9075 SPEAEHEAD WAY RENO, NEVADA 89506

SILVER KNOLLS; 11505 CIMARRON

2. LOCATION N½ ¼ ¼ Sec. 24 T. 21 N/S R. 18 E. WASHOE County

PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
surface clay		0	14	14
brown clay		14	97	83
clay with rocks		97	177	80
coarse sand	XX	177	181	4
brown clay w/cobblestones		181	219	38
sand	XX	219	238	19
brown clay		238	240	2

Date started June 25, 19 78
Date completed June 28, 19 78

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 12¼ inches Total depth 240 feet
Casing record 8 5/8" od
Weight per foot 16.94 Thickness 188 wall

Diameter	From	To
12¼ inches	0 feet	240 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type cement
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 240 feet

Perforations:
Type perforation Milled
Size perforation 1/8" x 3"
From 160 feet to 240 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 155 Feet below land surface
Flow G.P.M.
Water temperature 56 °F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name SAGE BROS DRILLING COMPANY, INC.
Address 1500 RANGER ROAD RENO, NV 89506
Nevada contractor's license number 7462A
Nevada driller's license number 774
Signed [signature]
Date July 11, 1978

USE ADDITIONAL SHEETS IF NECESSARY

5471