WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 18739
Permit No.
Basin

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER FRONTIER INC. ADDRESS 335 E 6th St. Reno, Nevada

7660 Tamara Golden Valley

2. LOCATION ¼ ¼ Sec. 10 T. 20 N/S R. 19 E. Washoe County

PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐ Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
top soil		0	1	1
brn. DG		1	15	14
green granit		15	65	50
brn white clay fract.				
green granit		65	75	10
green granit fract at 97 ft.		75	100	25
green granit hard		100	195	95
green granite fract.		195	215	20
green granit fract.	xx	215	250	35

Date started 8/12/78, 19
Date completed 8/12/78, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 6" inches Total depth 250 feet
Casing record 250
Weight per foot Thickness 156

Diameter	From	To
6 5/8 inches	0 feet	250 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type cement
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 250 feet

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 2½ x 6 around
From 207 feet to 247 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 145 Feet below land surface
Flow 20 G.P.M.
Water temperature °F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WAYNE DRILLING INC.
Address P. O. Box 12370 Reno, Nev. 89510
Nevada contractor's license number 14043
Nevada driller's license number 923
Signed Ed Mondragon
Date 8-18-78

USE ADDITIONAL SHEETS IF NECESSARY

5471

OFFICE
STATE ENGINEER

1978 AUG 21 AM 11 12