

Log No. 18762
 Permit No. _____
 Basin _____

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER SECURITY HOUSING ADDRESS 102 VASTAR ST - Reno
10300 BIGHORN DR - SILVER KNOLLS
 2. LOCATION E 1/4 E 1/4 Sec. 26 T 2 N/S R. 18 E WASHOE County
 PERMIT NO. _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown Clay		0	5	5
DC		5	60	55
Brown Clay		60	120	60
Blue Clay		120	240	120
Washed Sand	Washed	240	260	20
Blue Clay		260	267	7

8. WELL CONSTRUCTION
 Diameter hole 10 inches Total depth 262 feet
 Casing record 6"
 Weight per foot 8.5 Thickness 10 Gauge
 Diameter From To
6 inches 0 feet 262 feet
 _____ inches _____ feet _____ feet
 Surface seal: Yes No Type CEMENT
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 262 feet
 Perforations:
 Type perforation Torch
 Size perforation 3/32
 From 202 feet to 262 feet
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level _____ Feet below land surface
 Flow _____ G.P.M.
 Water temperature _____ ° F. Quality _____

Date started Aug 11, 1978
 Date completed Aug 16, 1978

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Suchts Well Drilling
 Address Sparks Rd
 Nevada contractor's license number 14508
 Nevada driller's license number 935
 Signed Larry Martin
 Date Aug 16 / 78