

**WELL DRILLERS REPORT**

Please complete this form in its entirety

1. OWNER Charles & Dorothy Wiltsie ADDRESS 1041 Sage View Dr., Sparks, Nevada  
Spanish Springs  
 2. LOCATION NE 1/4 NE 1/4 Sec. 20 19 T. 21 N/S R. 21 E. Washoe County  
 PERMIT NO. ....

3. TYPE OF WORK		4. PROPOSED USE			5. TYPE WELL	
New Well <input checked="" type="checkbox"/>	Recondition <input type="checkbox"/>	Domestic <input checked="" type="checkbox"/>	Irrigation <input type="checkbox"/>	Test <input type="checkbox"/>	Cable <input type="checkbox"/>	Rotary <input checked="" type="checkbox"/>
Deepen <input type="checkbox"/>	Other <input type="checkbox"/>	Municipal <input type="checkbox"/>	Industrial <input type="checkbox"/>	Stock <input type="checkbox"/>	Other <input type="checkbox"/>	Air <input type="checkbox"/>

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
sand broken brn. rock		0	10	10
gray granit rock		10	80	70
brn clay w/DG		80	130	50
gray granit rock		130	365	235
gray granit rock fract. x		365	370	5
gray granit rock x		370	475	105
fract 450 475				
gray granit hard no water		475	480	5
Deepened by log # 30007 3/91				

8. WELL CONSTRUCTION

Diameter hole 6 inches Total depth 480 feet  
 Casing record 480  
 Weight per foot ..... Thickness 1.56

Diameter	From	To
<u>6 5/8</u> inches	<u>0</u> feet	<u>480</u> feet
..... inches	..... feet	..... feet
..... inches	..... feet	..... feet
..... inches	..... feet	..... feet
..... inches	..... feet	..... feet
..... inches	..... feet	..... feet

Surface seal: Yes  No  Type cement  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from 50 feet to 480 feet

Perforations:  
 Type perforation factory sawed slot  
 Size perforation 3/32 x 2 1/2 x 6 around  
 From 460 feet to 480 feet  
 From 330 feet to 380 feet  
 From ..... feet to ..... feet  
 From ..... feet to ..... feet  
 From ..... feet to ..... feet

Date started 9/12/78, 19  
 Date completed 9/14/78, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M.	Draw down	feet	hours

9. WATER LEVEL

Static water level 240 Feet below land surface  
 Flow 15 G.P.M.  
 Water temperature ..... ° F. Quality .....

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WAYNE DRILLING INC.  
 Address P.O. Box 12370 Reno, Nev. 89510  
 Nevada contractor's license number 14043  
 Nevada driller's license number 923  
 Signed Ed Mendragon  
 Date 9-19-78