WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 18791
Permit No.
Basin

1. OWNER Lyman Rummel ADDRESS 3000 Batger St Silver Springs, Nev.

2. LOCATION SW ¼ SE ¼ Sec. 31 T. 17 N/S R. 25 E. Lyon County
PERMIT NO. Lot 168 Stockton Sub.

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☑ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0'	4'	04'
Yellow Clay		4'	14'	10'
Sand	X	14'	44'	30'
Clay + Sand	X	44'	78'	34'
Sand		78'	82'	04'
Clay	X	82'	88'	06'
Sand		88'	100'	12'
Sand + some clay		100	104'	04'
		TOTAL		104'

Date started 9/19/78, 19
Date completed 9/22/78, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	10	0	

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. 0 to 50 = 12" WELL CONSTRUCTION
Diameter hole 8 inches Total depth 104 feet
Casing record 8"
Weight per foot 16.5 Thickness 188

Diameter	From	To
8 inches	0 feet	104 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☐ No ☐ Type Cement
Depth of seal 50 feet
Gravel packed: Yes ☐ No ☑
Gravel packed from feet to feet

Perforations:
Type perforation Factory
Size perforation 3" x 3/32
From 84 feet to 104 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 50 Feet below land surface
Flow G.P.M. 10
Water temperature Cold °F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name W. M. Blain Well Drilling
Address Box 353 Dayton, Nev. 89403
Nevada contractor's license number 10950
Nevada driller's license number 963
Signed R. E. O'Farrell
Date 9/22/78

USE ADDITIONAL SHEETS IF NECESSARY

5471