

Log No. 18937
 Permit No. _____
 Basin _____

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Security Housing ADDRESS 100 Vassar Street
15420 Cherrywood Reno, Nevada 89502
 2. LOCATION SW 1/4 SE 1/4 Sec 2 T. 17N N/S R. 19 E Washoe County
 PERMIT NO. 275

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Black, white brown, cobble-stone sand, DG coarse to 1/2"		0	8	8
Black, brown DG, clay 1/4"		8	11	3
Black, white, brown, D.G. cobbles, clay 20%		11	30	19
White, black sand rounded mica 1/8" to flakes		30	35	5
Black, white, red sand & gravel fine to coarse 1/4"		35	50	15
Black, white, red, brown, gravel, sand, clay 10% coarse 1/4"		50	95	45
Multi brown, gravel, clay 60% coarse 1/4"		95	110	15
Multi brown gravel, clay 30% Coarse		110	120	10

8. WELL CONSTRUCTION
 Diameter hole 6 5/8 inches Total depth 126 feet
 Casing record XXXX 0-126' x 6 5/8
 Weight per foot 12.89 Thickness .188

Diameter	From	To
<u>6 5/8</u> inches	<u>0</u> feet	<u>126</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type Cement
 Depth of seal 50' feet
 Gravel packed: Yes No
 Gravel packed from 126 feet to 65 feet
 Perforations:
 Type perforation Factory mill slot
 Size perforation .060 x 2 1/2
 From 82 feet to 106 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 50 Feet below land surface
 Flow _____ G.P.M.
 Water temperature _____ ° F. Quality _____

Date started 18 August, 19 78
 Date completed 21 August, 19 78

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Air Blown:	20 GPM @ 85'	depth	
	30 GPM @ 100'	depth	

BAILER TEST

G.P.M.	Draw down	feet	hours
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name W.L. McDonald & Co., Inc.
 Address P.O. Box 404 Sparks, Nevada
 Nevada contractor's license number 9767
 Nevada driller's license number 805
 Signed Tony Betita by W.L. McDonald
 Date 23 August, 1978