

OFFICE USE ONLY  
 Log No. 18781  
 Permit No. \_\_\_\_\_  
 Basin \_\_\_\_\_

**WELL DRILLERS REPORT**

Please complete this form in its entirety

Sparks

1. OWNER Pat Meadows ADDRESS 1521 Breaker Way #444, Nev.

2. LOCATION se 1/4 SW 1/4 Sec. 21 T. 15 N/S R. 19 E. Washoe CARSON County  
 PERMIT NO. 282

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

| Material                  | Water Strata | From | To  | Thick-ness |
|---------------------------|--------------|------|-----|------------|
| Clay & Small Rock         |              | 0    | 155 | 155        |
| Gravel                    | w/s          | 155  | 160 | 5          |
| Sand & Clay               |              | 160  | 195 | 35         |
| Gravel                    | w/s          | 195  | 215 | 20         |
| Sand & Clay               |              | 215  | 235 | 20         |
| Gravel                    | w/s          | 235  | 250 | 15         |
| Well rock ed back to 245' |              |      |     |            |

8. WELL CONSTRUCTION  
 Diameter hole 8 1/8 inches Total depth 250 feet  
 Casing record \_\_\_\_\_  
 Weight per foot \_\_\_\_\_ Thickness 188  

| Diameter     | From       | To         |
|--------------|------------|------------|
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |

 Surface seal: Yes  No  Type Ready Mix  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Perforations:  
 Type perforation Factory  
 Size perforation 1/16  
 From 150 feet to 250 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 9-14-78, 19\_\_\_\_\_  
 Date completed 9-26-78, 19\_\_\_\_\_

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|----------|--------|-----------|------------------|
|          |        |           |                  |
|          |        |           |                  |
|          |        |           |                  |
|          |        |           |                  |

BAILER TEST  
 G.P.M. 20 Draw down 0 feet 5 hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

9. WATER LEVEL  
 Static water level 160 Feet below land surface  
 Flow \_\_\_\_\_ G.P.M. 20  
 Water temperature \_\_\_\_\_ ° F. Quality \_\_\_\_\_

10. DRILLERS CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Jim House & Sons Drilling  
 Address P.O. Box 2192 Carson City, Nev.  
 Nevada contractor's license number 12554  
 Nevada driller's license number 651  
 Signed Steve House  
 Date 10-15-78