WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 18984
Permit No.
Basin

1. OWNER Skyf Builder ADDRESS Gardnerville - Nevada

2. LOCATION ¼ ¼ Sec. 22 T. 13 N/S R. 19 E. Douglas County
PERMIT NO. Lot # 11 - Foothill Acres - Doc. # 15119 - Recorded 1977 - Book

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Set conc				
Soft DG -		0	20	20
Decomposed Granit		20	80	60
Decomposed Granit - Rock - Broken		80	97	17
Water at 35 feet - water all the way - to 97 feet.				
				97

Date started Oct 10, 1978
Date completed Oct 13, 1978

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 20 Draw down 0 feet 2 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 8 inches Total depth feet
Casing record
Weight per foot 14 lb. Thickness .185

Diameter	From	To
8 5/8 O.D. inches	0 feet	97 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 50 + feet
Gravel packed: Yes ☐ No ☐
Gravel packed from feet to feet

Perforations:
Type perforation Factory
Size perforation 1/16 x 3
From 77 feet to 97 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 35 Feet below land surface
Flow G.P.M.
Water temperature 56 ° F. Quality Good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Austin W. Graham
Address Gardnerville - Nevada
Nevada contractor's license number 12953
Nevada driller's license number 751
Signed A. W. Graham
Date Oct 14 - 1978

USE ADDITIONAL SHEETS IF NECESSARY

5471