WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PAGE 1 of 2

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 19065
Permit No. 34636
Basin 153

1. OWNER PAUL ANSPACH FOR LAMCO INC ADDRESS 1845 MANZANITTA Dr.
RENO NV 89509

2. LOCATION SW ¼ SW ¼ Sec. 4 T. 22 N R. 54 E. EUREKA County
PERMIT NO. 34636

3. TYPE OF WORK
New Well ☐ Recondition ☐
Deepen ☐ Other ☒ REPLACEMENT

4. PROPOSED USE
Domestic ☒ Irrigation ☒ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐ REVERSE

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Topsoil		0	2	
S+G = Sand+gravel		2	15	
Black+gray clay		15	143	
FBS=Fineblacksand		143	154	
gray clay		154	163	
FBS		163	174	
clay		174	179	
FBS		179	184	
clay		184	209	
FBS		209	211	
clay		211	216	
FBS		216	219	
clay		219	224	
FBS		224	235	
clay		235	250	
heaving clay		250	270	
sandstone		270	275	
S+G claytraces		275	278	
clay		278	290	
S+G clay traces		290	296	
clay		296	311	
sandstone		311	313	
S+G		313	314	
clay		314	316	
S+G		316	317	
heaving clay		317	321	

continued on page (2)

Date started 10-16, 1978
Date completed 10-20, 1978

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
39.812333°N		Plugged by	
115.902219°W			NOI #62306
	NAD 27		
	(TA)		

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 29 inches Total depth 454 feet
Casing record
Weight per foot 16" Thickness .250

Diameter	From	To
16" inches	0 feet	206 feet
12 3/4 inches	206 feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☐ No ☒ Type
Depth of seal feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 0 feet to 464 feet

Perforations: ROSCOE MOSS STD +
Type perforation Full Flow
Size perforation 3/32
From STD 271 feet to 319 feet
From Full Flow 319 feet to 343 feet
From Full Flow 357 feet to 453 feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 19 Feet below land surface
Flow 0 G.P.M.
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name PLASKETT IRRIGATION CO.
Address PO Box 8 Eureka NV
Nevada contractor's license number 11882
Nevada driller's license number 706
Signed Walter Plaskett
Date 10-31-78

USE ADDITIONAL SHEETS IF NECESSARY

5471

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PAGE 2 of 2

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 19065
Permit No. 34636
Basin 153

1. OWNER P. Anspach ADDRESS

SEE PG -1-

2. LOCATION ¼ ¼ Sec. T. N/S R. E. County
PERMIT NO. 34636

3. TYPE OF WORK
New Well ☐ Recondition ☐ PAGE
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☐
Other ☐

6. Cont. from -1- LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
S+G		321	323	
clay		323	349	
S+G		349	354	
clay		354	379	
S+G		379	383	
clay		383	384	
S+G with clay traces		384	403	
clay		403	404	
S+G		404	407	
clay		407	423	
S+G		423	425	
Hard clay - some cemented		425	433	
S+G		433	434	
clay		434	436	
narrow streaks - S+G		436		
and cemented gravel and				
clay - all to narrow to				
define			453	
clay		453	464	

Date started ....., 19....
Date completed ....., 19....

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole ..... inches Total depth ..... feet
Casing record .....
Weight per foot ..... Thickness .....

Diameter	From	To
SEE	inches feet	feet
	inches feet	feet
	inches feet	feet
PAGE	inches feet	feet
	inches feet	feet
	inches -1- feet	feet

Surface seal: Yes ☐ No ☐ Type .....
Depth of seal ..... feet
Gravel packed: Yes ☐ No ☐
Gravel packed from ..... feet to ..... feet

Perforations:
Type perforation .....
Size perforation .....
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level ..... Feet below land surface .....
Flow ..... G.P.M. .....
Water temperature ..... ° F. Quality .....

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Plaskett Irrigation Co.
Address PO Box 8 Eureka, Nv
Nevada contractor's license number 11882
Nevada driller's license number 706
Signed Walton Plaskett
Date 10-31-78

USE ADDITIONAL SHEETS IF NECESSARY

5471